

(1) **HOMOLOGATION - ATELIERS DE RÉPARATION  
(PROLONGATION)**  
(2) **Appareils ou systèmes de protection ou composants destinés à être utilisés  
en atmosphères explosibles  
Directive 94/9/CE**

(3) Numéro de l'homologation : **ISSEP07INES015/2**

(4) Appareils ou systèmes de protection ou composants tels qu'énumérés :  
- Machines tournantes (moteurs & générateurs).  
- Modes de protection : Ex d, Ex e, Ex p, Ex n & Ex t.

(5) Réparateur  
Nom : **MAINTENANCE PARTNERS BELGIUM nv**  
  
Adresse : **Vitshoekstraat 6, Haven 1035  
2070 Zwijndrecht  
Belgique**

(6) La présente homologation repose sur le rapport d'audit n° 13030 du 29.04.2013.

La présente homologation peut être retirée si le réparateur ne satisfait plus aux exigences des normes CEI 60079-19, EN 60079-0, EN 60079-1, EN 60079-2, EN 60079-7, EN 60079-15 & EN 60079-31.

**Les résultats d'une réévaluation périodique du réparateur font partie de cette présente homologation.**

(7) La validité de la présente homologation prend fin le 17.04.2016. L'homologation peut être retirée si le réparateur ne satisfait pas à la réévaluation périodique.

(8) Les appareils, systèmes de protection ou composants réparés seront marqués conformément à l'annexe A de la norme CEI 60079-19.

Colfontaine, le 24.05.2013.

INSTITUT SCIENTIFIQUE DE SERVICE PUBLIC  
Zoning A. Schweitzer, rue de la Platinerie  
B-7340 COLFONTAINE (Wasmès)  
Tél: ++ 32 65 610811 – Fax: ++ 32 65 610808  
colfontaine@issep.be

  
Marcel LAMBERT,  
Directeur.

## HOMOLOGATION - ATELIERS DE RÉPARATION N° ISSeP07INES015/2

### ANNEXE

#### Liste des appareils ou des systèmes de protection ou des composants couverts par la présente notification

- Machines tournantes (moteurs & générateurs).
- Modes de protection : Ex d, Ex e, Ex p, Ex n & Ex t.

#### Documentation technique descriptive

- L'homologation ISSeP07INES015 et sa surveillance n° 1.
- Le rapport ISSeP n° 13030 du 29.04.2013 relatif à la surveillance n° 2.
- Sept documents relatifs à cette surveillance n° 2.

#### Validité

- Date de délivrance de la notification originale : 17.04.2007.
- Date de délivrance de la présente prolongation : 24.05.2013.
- Date d'expiration de la présente prolongation : 17.04.2016.

(1) **OFFICIAL APPROVAL - REPAIRING WORKSHOPS  
(EXTENSION)**  
(2) **Equipment or protective systems or components intended for use  
in potentially explosive atmospheres  
Directive 94/9/EC**

(3) Approval number: **ISSeP07INES015/2**

(4) Equipment or protective systems or components as listed:  
- Rotating Machines (Motors & Generators).  
- Types of protection: Ex d, Ex e, Ex p, Ex n & Ex t.

(5) Repairer  
Name: **MAINTENANCE PARTNERS BELGIUM nv**  
  
Address: **Vitshoekstraat 6, Haven 1035  
2070 Zwijndrecht  
Belgium**

(6) This notification is based on audit report N° 13030 of 29.04.2013.

This Approval can be withdrawn if the Repairer no longer satisfies the requirements of Standards IEC 60079-19, EN 60079-0, EN 60079-1, EN 60079-2, EN 60079-7, EN 60079-15 & EN 60079-31.

**Results of periodical reassessment of the Repairer are a part of this Approval.**

- (7) This Approval is valid until 17.04.2016 and can be withdrawn if the Repairer does not satisfy the periodic reassessment.
- (8) Repaired equipment, protective systems or components will be marked according to Annex A of Standard IEC 60079-19.

Colfontaine, the 24.05.2013.

INSTITUT SCIENTIFIQUE DE SERVICE PUBLIC  
Zoning A. Schweitzer, rue de la Platinerie  
B-7340 COLFONTAINE (Wasmès)  
Tél: ++ 32 65 610811 – Fax: ++ 32 65 610808  
colfontaine@issep.be

  
Marcel LAMBERT,  
Director.

This Official Approval may only be reproduced in its entirety and without any change, eventual schedule included

## OFFICIAL APPROVAL - REPAIRING WORKSHOPS ISSeP07INES015/2

### SCHEDULE

#### List of equipment or protective systems or components covered by this notification

- Rotating Machines (Motors & Generators).
- Types of protection: Ex d, Ex e, Ex p, Ex n & Ex t.

#### Technical descriptive documentation

- Notification ISSeP07INES015 with extension N° 1.
- Report ISSeP N° 13030 of 29.04.2013 related to the extension N° 2.
- Seven documents related to this extension N° 2.

#### Extension of validity

- Delivery date of the original notification: 17.04.2007.
- Delivery date of this extension: 24.05.2013.
- Expire date of this extension: 17.04.2016.